

| | |
|----------------------|--|
| Issued by | NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2009/23/EC, after having established that the measuring instrument meets the applicable requirements of Directive 2009/23/EC, to: |
| Manufacturer | Shinko Denshi Co., Ltd. 3-9-11 Yushima, Bunkyo-ku Tokyo 113-0034 Japan |
| Measuring instrument | A Non-automatic weighing instrument Type : AJ[H], AJ[H]P, AJ for carat (CT), SJ or SJP |
| Valid until | 5 November 2022 |
| Remarks | Further properties are described in the annexes: – Description T6124 revision 6; – Documentation folder T6124-5. This revision replaces the earlier versions, except for its documentation folder. |

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
5 November 2012

C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see www.nmi.nl).

Reproduction of the complete document only is permitted.

1 General information about the non-automatic weighing instrument

All properties of the non-automatic weighing instrument, whether mentioned or not, shall not be in conflict with the legislation.

1.1 Essential parts

See drawings:

- AJ-CE/AJH-CE/AJP-CE/AJHP-CE Block Diagram 1, drawing number 20YE001 rev. 2.1;
- AJ-CE/AJH-CE/AJP-CE/AJHP-CE Block Diagram 2, drawing number 20YE002 rev. 1.1;
- SJP Block Diagram 1, drawing number 21YE001;
- SJP Block Diagram 2, drawing number 21YE002.

The electronics;

The mechanical assembly with weighing cell.

EMC protection measures:

- See AJ-CE/AJH-CE/AJP-CE/AJHP-CE Block Diagram 2, drawing number 20YE002 rev. 1.1 or;
- See SJP Block Diagram 2, drawing number 21YE002;
- The weighing cell is shielded with a metal cover;
- Filter in the incoming power line;
- Ferrite (5 loops) around the power supply cable to the main board;
- Ferrite (1 loop) around the cable between main board and calibration weight unit mechanism;
- The weighing mechanism is connected to ground.

1.2 Essential characteristics

| Accuracy class | (I) | (II) |
|-----------------------------------|--|---|
| Maximum capacity | $500 \text{ g} \leq \text{Max} \leq 6200 \text{ g}$ $2500 \text{ ct} \leq \text{Max} \leq 31000 \text{ ct}$ | $50 \text{ g} \leq \text{Max} \leq 12 \text{ kg}$ $250 \text{ ct} \leq \text{Max} \leq 60000 \text{ ct}$ |
| Verification scale interval | $e \geq 0,01 \text{ g}$ or $e \geq 0,1 \text{ ct}$ $e = d$ or $e = 10d$ | |
| Maximum number of scale intervals | $n \leq 82000$ divisions | $n \leq 42000$ divisions |
| Temperature range | $+10 \text{ }^\circ\text{C}$ / $+30 \text{ }^\circ\text{C}$ | |
| Weighing range(s) | Single interval | |
| Power supply voltage | 9 or 12 V DC supplied by AC/DC adapter or by internal battery. | |

1.3 Essential shapes

The non-automatic weighing instrument is built according to the drawings:

- AJ(H) and AJ(H)P-220CE~620CE External View, drawing number 20YM069 rev. 0.1;
- AJ and AJP-820CE~1200CE External View, drawing number 20YM070 rev. 0.1;
- CT and CT-DB External View, drawing number 20YM072 rev. 0.1;
- AJ(H)-2200~12KCE External View, drawing number 20YM071 rev. 0.1;
- CT-T and CT-TDB External View, drawing number 20YM073 rev. 0.1;
- SJ(P)-220~820CE External View, drawing number 20YM074 rev. 0.1;
- SJ(P)-1200CE External View, drawing number 20YM075 rev. 0.1;
- SJ(P)-2200~12KCE External View, drawing number 20YM076 rev. 0.1.

The descriptive markings plate is secured against removal by sealing or will be destroyed when removed.

Inside the cabinet is a calibration lock, located on the main board.

1.4 Conditional parts

The non-automatic weighing instrument may be equipped with peripheral equipment which is used for the applications listed in article 1(2)(a) of Directive 2009/23/EC, provided that the peripheral equipment is certified to be connected to an EC type-approved non-automatic weighing instrument by a Notified Body responsible for type examination under Directive 2009/23/EC, or that the equipment and the use of the equipment comply with the requirements of WELMEC 2.5 Issue 2 Section 2.2.

The non-automatic weighing instrument is fitted with a levelling device and a level indicator, unless the instrument is installed in a fixed position. The level indicator has a sensitivity of at least 2 mm for a tilt of 2/1000.

1.5 Non-essential parts

The non-automatic weighing instrument may be connected to non-essential devices, for example but not limited to bar code readers, foot switches, second display's and cash drawers, provided that:

- They do not present primary data used for purposes mentioned in article 1(2)(a) of Directive 2009/23/EC unless the "preliminary observations" in Annex 1 of this directive is satisfied;
- They do not lead to an instrument having other essential characteristics than those fixed by this type-approval document.

Windscreen over the load receptor (in case of type AJ(H)-220CE/-320CE/-420CE/-620CE and AJ(H)P); AC/DC-adapter.

2 Information about the main constituent parts of the non-automatic weighing instrument

2.1 The electronics

2.1.1 Essential parts

| Number | Pages | Description | Remarks |
|----------|-------|---------------------------------------|---------|
| 20YE004 | 1 | AJDP PCB Parts Assignment | rev 1.1 |
| 21YE004 | 1 | SJP-DP PCB Parts Assignment | rev 1.1 |
| AJDP PCB | 1 | Parts list AJ / AJH / SJ / SJP series | - |

2.1.2 Essential characteristics

List of legally relevant functions:

- Determination stability of equilibrium;
- Zero indicator;
- Zero-tracking;
- Combined initial zero-setting and subtractive tare balancing;
- Combined semi-automatic zero-setting and subtractive tare balancing;
- Indication of stable equilibrium;
- Semi-automatic span adjustment with internal calibration mass (optional for class $\textcircled{\text{II}}$);
- Semi-automatic span adjustment with internal or external calibration mass (only for class $\textcircled{\text{I}}$);
- Calibration / set-up mode via a switch on the main board;
- Acting upon significant faults;
- Checking the display;
- Weight unit selection (g, ct, %, pcs);
- Auxiliary indication with differentiated scale division (optional).

2.1.3 Conditional parts

| Number | Pages | Description | Remarks |
|---------|-------|------------------------------------|----------------------|
| 20YE006 | 1 | PCB lay-out of Battery unit DJBT-1 | Including parts list |

The non-automatic weighing instrument may be equipped with one or more of the following protective interfaces that have not to be secured:

- RS232C.

2.1.4 Non-essential parts

Display;
 Keyboard.

2.1.5 Non-essential characteristics

- Check weighing mode (=limit function);
- Percentage weighing mode;
- Piece counting mode.

2.2 The mechanical assembly with load cell

2.2.1 Essential parts

| Number | Pages | Description | Remarks |
|---------|-------|---|---------|
| 20YM007 | 1 | View of Components AJ-CE /AJ-SCE/AJH-CE | rev 1.1 |
| 20YM013 | 1 | View of Components AJ / AJH / SJ / SJP | rev 1.1 |
| 20YM019 | 1 | View of Components AJ for carat (CT) | rev 1.1 |
| 20YM004 | 1 | Mechanical Unit | - |
| 20YM012 | 1 | Mechanical Unit | - |

2.2.2 Essential characteristics

Maximum capacity of the weighing cell in case of class **I**:

- Max = 820 g with e = 0,01 g;
- Max = 6200 g with e = 0,1 g.

Maximum capacity of the weighing cell in case of class **II**:

- Max = 420 g with e = 0,01 g;
- Max = 4200 g with e = 0,1 g;
- Max = 12 kg with e = 1 g.

2.2.3 Essential shapes

See drawings:

- Mechanical Unit, drawing number 20YM004;
- Mechanical Unit, drawing number 20YM012.

3 Seals

To secure components that may not be dismantled or adjusted by the user, the non-automatic weighing instrument has to be secured in a suitable manner on the locations indicated in the drawings:

- AJ(H) and AJ(H)P-220CE~620CE External View, drawing number 20YM069 rev. 0.1;
- AJ and AJP-820CE~1200CE External View, drawing number 20YM070 rev. 0.1;
- CT and CT-DB External View, drawing number 20YM072 rev. 0.1;
- AJ(H)-2200~12KCE External View, drawing number 20YM071 rev. 0.1;
- CT-T and CT-TDB External View, drawing number 20YM073 rev. 0.1;
- SJ(P)-220~820CE External View, drawing number 20YM074 rev. 0.1;
- SJ(P)-1200CE External View, drawing number 20YM075 rev. 0.1;
- SJ(P)-2200~12KCE External View, drawing number 20YM076 rev. 0.1.

4 Conditions for conformity assessment

The marks, facilities for the marks and the inscriptions on the non-automatic weighing instrument fulfill the requirements of article 1 of Annex IV of Directive 2009/23/EC.